



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Tim Davis
Executive Director

DIVISION OF AIR QUALITY
Bryce C. Bird
Director

DAQE-NN162210002-25

November 13, 2025

Salt Lake Tribune
Legal Advertising Dept.
P.O. Box 704055
West Valley City, UT 84170
Acct #9001399880

RE: Legal Notice of Intent to Approve

This letter will confirm the authorization to publish the attached NOTICE in the Salt Lake Tribune on November 16, 2025.

Please mail the invoice and affidavit of publication to the Utah State Department of Environmental Quality, Division of Air Quality, P.O. Box 144820, Salt Lake City, Utah 84114-4820. If you have any questions, contact Jeree Greenwood, who may be reached at (385) 306-6514.

Sincerely,

Jeree Greenwood
Office Technician

Enclosure

cc: Salt Lake County
cc: Wasatch Front Regional Council

NOTICE

A Notice of Intent for the following project submitted in accordance with R307-401-1, Utah Administrative Code (UAC), has been received for consideration by the Director:

Company Name: Aligned Energy Data Centers (SLC), LLC.
Location: Aligned Data Centers (WJU) PropCo, LLC. - West Jordan Data Center – 6800 West 9800 South, West Jordan, UT

Project Description: Aligned Data Centers (WJU) PropCo, LLC (Aligned) operates a data center power station in West Jordan, Salt Lake County. The data center runs on line power. One hundred ninety-two (192) diesel-fueled emergency engines are used to provide power in the event of an emergency. Each emergency engine has a designated diesel fuel storage tank.

Aligned has requested a modification to Approval Order (AO) DAQE-AN162210001-24, dated November 19, 2024, for the following changes:

1. Add twelve (12) simple cycle natural gas-fired turbines (turbines) to provide primary power for the data center buildings.
2. Reduce the quantity of 3,100-kilowatt (kW) diesel-fired emergency generators (Equipment ID# II.A.2 in 2024 AO) and the associated fuel storage tanks from one hundred eight-two (182) to one hundred twelve (112).
3. Reduce the quantity of 1,000 kW diesel-fired emergency generators (Equipment ID# II.A.3 in 2024 AO) and associated fuel storage tanks from ten (10) to seven (7).

The West Jordan Data Center has the potential to emit more than 50 tons per year of NO_x and is located in Salt Lake County. Therefore, this project requires an emission offset of 1.2:1 under Utah Administrative Code Rule R307-421 (Permits: PM₁₀ Offset Requirements in Salt Lake County and Utah County).

The completed engineering evaluation and air quality impact analysis showed the proposed project meets the requirements of federal air quality regulations and the State air quality rules. The Director intends to issue an Approval Order pending a 30-day public comment period. The project proposal, estimate of the effect on local air quality, and draft Approval Order are available for public inspection and comment at the Utah Division of Air Quality, 195 North 1950 West, Salt Lake City, UT 84116. Written comments received by the Division at this same address on or before December 16, 2025, will be considered in making the final decision on the approval/disapproval of the proposed project. Email comments will also be accepted at cbodell@utah.gov. If anyone so requests to the Director in writing within 15 days of publication of this notice, a hearing will be held in accordance with R307-401-7, UAC.

Under Section 19-1-301.5, a person who wishes to challenge a Permit Order may only raise an issue or argument during an adjudicatory proceeding that was raised during the public comment period and was supported with sufficient information or documentation to enable the Director to fully consider the substance and significance of the issue. **Date of Notice: November 16, 2025**