State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Tim Davis
Commissioner

DIVISION OF AIR QUALITY
Bryce C. Bird
Director

DAQE-NN163220001-26

August 27, 2026

Salt Lake Tribune
Legal Advertising Dept.
P.O. Box 704055
West Valley City, UT 84170
Acct #9001399880

RE: Legal Notice of Intent to Approve

This letter will confirm the authorization to publish the attached NOTICE in the Salt Lake Tribune on August 30, 2026.

Please mail the invoice and affidavit of publication to the Utah State Department of Environmental Quality, Division of Air Quality, P.O. Box 144820, Salt Lake City, Utah 84114-4820. If you have any questions, contact Jeree Greenwood, who may be reached at (385) 306-6514.

Sincerely,

Jeree Greenwood

Jeree Greenwood
Office Technician

Enclosure

cc: Salt Lake County
cc: Wasatch Front Regional Council

NOTICE

A Notice of Intent for the following project submitted in accordance with R307-401-1, Utah Administrative Code (UAC), has been received for consideration by the Director:

Company Name: Will-Power UT, LLC
Location: Will-Power UT, LLC - Eagle Mountain Power Generation Facility – 247 North Pony Express Parkway, Eagle Mountain, UT

Project Description: Will-Power UT, LLC (Will-Power) proposes to construct and operate a new power generation facility in Eagle Mountain, Utah - Eagle Mountain Power Generation. The facility is located at 247 North Pony Express Parkway, Eagle Mountain, UT 84005, within an area of Utah County designated as a marginal nonattainment area of the National Ambient Air Quality Standards (NAAQS) for 2015 8-hour ozone and as a maintenance area of particulate matter with an aerodynamic diameter of 10 microns or less (PM_{10}). The project will consist of 17 natural gas-fired simple cycle turbines (natural gas turbines), eight (8) ultra-low NO_x natural gas-fired line heaters (line heaters), two (2) natural gas-fired emergency generator engines (natural gas engines), and one (1) diesel-fired emergency fire pump engine (fire pump engine) and associated diesel belly tank. The proposed installation will provide primary power exclusively and directly to a nearby data center.

The completed engineering evaluation and air quality impact analysis showed the proposed project meets the requirements of federal air quality regulations and the State air quality rules. The Director intends to issue an Approval Order pending a 30-day public comment period. The project proposal, estimate of the effect on local air quality, and draft Approval Order are available for public inspection and comment at the Utah Division of Air Quality, 195 North 1950 West, Salt Lake City, UT 84116. Written comments received by the Division at this same address on or before September 29, 2026, will be considered in making the final decision on the approval/disapproval of the proposed project. Email comments will also be accepted at jjenks@utah.gov. If anyone so requests to the Director in writing within 15 days of publication of this notice, a hearing will be held in accordance with R307-401-7, UAC.

Under Section 19-1-301.5, a person who wishes to challenge a Permit Order may only raise an issue or argument during an adjudicatory proceeding that was raised during the public comment period and was supported with sufficient information or documentation to enable the Director to fully consider the substance and significance of the issue. **Date of Notice: August 30, 2026**